

# Display energy certificate (DEC)

City of Wolverhampton College  
CONSTRUCTION CENTRE  
City of Wolverhampton College  
Bilston Campus, Wellington Road  
BILSTON  
WV14 6BT

Operational rating

# B

Certificate number: 1613-2316-3992-8022-5902

Valid until: 31 December 2026

Total useful floor area: 4,885.29 square metres

## Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO<sub>2</sub>) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

## Previous operational ratings

Date	Operational rating
January 2026	48 B
January 2025	59 C
January 2024	53 C

## Total carbon dioxide (CO<sub>2</sub>) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO<sub>2</sub>.

Date	Electricity	Heating	Renewables
January 2026	145	66	0
January 2025	163	95	0
January 2024	141	95	0

## Assessment details

Assessor's name	Michael Davies
Employer/Trading name	M J Davies Management Associates Ltd T/A Davi
Employer/Trading address	36 Cranham Close, Headless Cross, Redditch, B97 5AY
Assessor's declaration	Not related to the occupier.
Accreditation scheme	Elmhurst Energy Systems Ltd
Issue date	27 February 2026
Nominated date	1 January 2026

Score	Operational rating	This building	Typical
0-25	<b>A</b>		
26-50	<b>B</b>	← <b>48 B</b>	
51-75	<b>C</b>		
76-100	<b>D</b>		
			100 ..
101-125	<b>E</b>		
126-150	<b>F</b>		
150+	<b>G</b>		

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m2/year)	54	69.36
Typical energy use (kWh/m2/year)	80	235.05
Energy from renewables	0.0%	0.0%