

# Display energy certificate (DEC)

City of Wolverhampton College  
THE NURSERY  
City of Wolverhampton College  
Bilston Campus, Wellington Road  
BILSTON  
WV14 6BT

Operational rating

**C**

Certificate number: 0221-5291-1136-7085-7004

Valid until: 27 February 2036

Total useful floor area: 315 square metres

## Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO<sub>2</sub>) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	<b>A</b>		
26-50	<b>B</b>		
51-75	<b>C</b>	<b>70 C</b>	
76-100	<b>D</b>		
			----- 100 -----
101-125	<b>E</b>		
126-150	<b>F</b>		
150+	<b>G</b>		

## Previous operational ratings

Date	Operational rating
February 2026	<b>70 C</b>
March 2016	<b>95 D</b>

## Total carbon dioxide (CO<sub>2</sub>) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO<sub>2</sub>.

Date	Electricity	Heating	Renewables
February 2026	9	5	0
March 2016	12	8	0

## Assessment details

Assessor's name	Michael Davies
Employer/Trading name	M J Davies Management Associates Ltd T/A Davi
Employer/Trading address	36 Cranham Close, Headless Cross, Redditch, B97 5AY
Assessor's declaration	Not related to the occupier.
Accreditation scheme	Elmhurst Energy Systems Ltd
Issue date	27 February 2026
Nominated date	28 February 2026

## This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m <sup>2</sup> /year)	53.99	75.13
Typical energy use (kWh/m <sup>2</sup> /year)	55.09	171.03
Energy from renewables	0.0%	0.0%

